

PRODUCT **400 4-SIDE SSG Cassette Series Curtainwall**
 2-1/2" x 8-3/4" (4-side structural glazed)

TEST RESULTS

		Silicone glazed		VHB glazed	
		1" IGU	1-1/16" IGU	1" IGU	1-1/16" IGU
Sound Transmission Class	STC	32	36	33	35
Outdoor – Indoor Transmission Class	OITC	26	30	27	30

Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)	
1" IGU: 1/4" clear 1/2" air 1/4" clear	1-1/16" IGU: 1/4" clear 1/2" air 5/16" clear


TEST LAB

Intertek
 York, PA 17406

Report Number	J0665.01-113-11-R0
Test Date	11/29/2018
Report Date	12/17/2018

Reference above report for complete test specimen description and data.

Tubelite Representative:

 (sign) 1/3/19 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

ASTM E90: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413: Standard Classification for Rating Sound Insulation

ASTM E1332: Standard Classification for Rating Outdoor-Indoor Transmission Class