



July 18, 2007

Re: 14650 Series Testing

T14650 Storefront was developed as a segment of our standard T14000 series storefront system, and has not been treated as a stand-alone product, with regard to performance testing. We would expect similar results for air infiltration and water penetration testing as those received for the standard 14000 system since the assembly, gaskets and method of draining water are the same. Due to the increased amount of aluminum exposed to the warm air (interior) side, we would expect to see improved thermal performance.

I have attached a copy of our most recent test report, for your use. I hope this meets your needs. If you need additional information, please contact me.

Respectfully submitted,

Steve DeYoung  
*Tubelite Engineering*