

PRODUCT **400 4-SIDE SSG Cassette Series Curtainwall**
 2-1/2" x 8-3/4" (4-side structural glazed)
 400CW and 400T back members

TEST RESULTS

		Silicone glazed	VHB glazed
Condensation Resistance Factor Frame	CRF_F	85	85
Condensation Resistance Factor Glass	CRF_G	71	71
Unit Size : 78-3/4" x 78-3/4" (glazed wall configuration)			
Glass makeup: 1" IGU 1/4" PPG Solarban 70XL 1/2" 90% Argon, Tri-seal Super Spacer Premium 1/4" Clear			

TEST LAB

Intertek
 York, PA 17406

	Silicone glazed	VHB glazed
Report Number	J0683.02-116-46-R0	J0684.02-116-46-R0
Test Date	12/11/2018	12/6/2018
Report Date	12/12/2018	12/14/2018

Reference above reports for complete test specimen description and data.

Tubelite Representative:  (sign) 1/3/2019 (date)
 Tim Fookes - Vice President of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.