

PRODUCT **T24650 Series Storefront**
 2" x 6-1/2" (single thermal barrier)

TEST RESULTS

Sound Transmission Class	STC	31
Outdoor – Indoor Transmission Class	OITC	25
Unit Size : 78-3/4" x 79" (glazed wall configuration)		
Glass makeup: 1" IGU ¼" clear ½" air aluminum spacer ¼" clear		

TEST LAB

INTERTEK – ATI
 York, PA 17406

Report Number	G2597.01-113-11
Test Date	09/28/16
Report Date	10/20/16

Reference ATI report #G2597.01-113-11 dated 10/20/16, for complete test specimen description and data.

Tubelite Representative:  (sign) 10/26/16 (date)
 Tim Fookes - Director of Engineering (title)

TEST METHODS

ASTM E90-09: Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

ASTM E413-10: Standard Classification for Rating Sound Insulation

ASTM E1332-10a: Standard Classification for Rating Outdoor-Indoor Transmission Class

ASTM E2235-04: Standard Test Method for Determination of Decay Rates for Use in Sound Insulation Test Methods