

PRODUCT **200 Series Curtainwall**
 2" x 7-3/4" (captured)

TEST RESULTS

Thermal Transmittance (BTU/hr-ft ² -°F)	U-FACTOR	0.50
Condensation Resistance Factor Frame	CRF_F	68
Condensation Resistance Factor Glass	CRF_G	68
Unit Size : 79-3/4" x 79-3/4" (glazed wall configuration)		
Glass makeup: 1" IGU ¼" Clear HS ½" Air, stainless steel warm edge spacer ¼" VE1-2M #3 (e=0.040) HS		

TEST LAB

Architectural Testing
(ATI)
 York, PA 17406

Report Number	B9230.02-116-46
Test Date	05/16/2012
Report Date	06/19/2016

Reference ATI report in above table for complete test specimen description and data.

Tubelite Representative:

 (sign) 2/14/2018 (date)
Tim Fookes - Vice President of Engineering (title)

TEST METHODS

Thermal Performance: AAMA 1503-09, Voluntary Test Method for Thermal Transmission and Condensation Resistance of Windows, Doors, and Glazed Wall Sections.